


**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

It is certified that an inspection team headed by **Sub Divisional Engineer/ Junior Engineer, Water Supply and Sanitation Sub Division Sehna at Barnala** inspected the **R P International Sen Sec School, Sehna** (As per the water test report no DWTL/BRR/2224/00065 dated 25/07/2023 of District WATER TESTING LAB BARNALA found that school has potable drinking water for students(**As chemical Test**) and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building.

The above is valid for a period of 1 (year) 2023-24


**President
Punjab Model School
Education Society, Sehna**


Signature with Seal
Executive Engineer
Name **W & Sanitation Division**
BARNALA
Designation


**Principal
R.P International Sen. Sec. School
(Sehna)**

DISTRICT WATER TESTING LABORATORY, BARNALA
Court Complex Barnala, Near Suvridha Kendra, Old Water Supply Scheme, Barnala
dwtlbarnala@gmail.com

To,

R.P International Sr. Sec. School ,Sehna (Barnala)
Sehna (Barnala)


No.: DWTL/BAR/2324/00065 Dated : 25/07/2023


Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 783 Dated: 13/07/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 21/07/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Barnala

D/A : Test Report


President
Punjab Model School
Education Society, Sehna


Authorized Signatory
For, District Water Testing Laboratory
Barnala


Principal
R.P International Sen. Sec. School
(Sehna)

DISTRICT WATER TESTING LABORATORY, BARNALA


Court Complex Barnala, Near Suvridha Kendra, Old Water Supply Scheme, Barnala
dwtlbarnala@gmail.com


TEST REPORT

Name & Address of Customer : R.P International Sr. Sec . School ,Sehna (Barnala) Sehna (Barnala)	Customer Reference No.	No : 783 Dated : 13/07/2023
	Sample Submitted by	Sh. Sanjeev Rai (J.E)
	Date of Sample Receipt	21/07/2023
	Analysis Starting Date	24/07/2023
	Analysis completion Date	25/07/2023

Discipline : Chemical Testing		Group: Water	
ULR No.:	TC10998230000102F	Sample Type :	Water
Test Report No.:	DWTL/BAR/2324/00065	Date of Issue :	25/07/2023
Registration no.:	DWTL/BAR/REG2324/00173	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	500 ml / Amber Colored Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	R.P international Sr. Sec. School VPO Sehna , Barnala (R.O) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Sehna	District :	Barnala
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.25	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	150	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	112	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	64	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	21	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	3	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method


President
Punjab Model School
Education Society, Sehna


Principal
R.P International Sen. Sec. School
(Sehna)